

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 2200-0226:100 Page 1 of 1

CATEGORY: Ceiling Suspension Systems/Panels

LISTEE: USG Interiors, 1000 Crocker Road, Westlake OH 44145
Contact: *Phil Shaeffer (312) 606-3738 Fax (312) 214-6629

DESIGN: Model PARALINE system. The suspended ceiling system is designed as a component of a listed floor/ceiling assembly. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions and applicable codes and ordinances.

MARKING: Steel framing members and acoustical panels identified with name of material, fire resistance classification and UL label on cartons and bundles.

APPROVAL: Listed as a 3-hour fire-rated floor/ceiling assembly when concrete topping thickness is 33"; and, a 2-hour fire-rated floor/ceiling assembly when concrete topping thickness is 22".

NOTE: Formerly 1250-0226:100

*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager